

P14PS01930
Amendment 0001

The purpose of this amendment is to post responses to vendor questions that have been submitted regarding the Combined Synopsis/Solicitation for the Mount Rainier Helibase Operations Support Trailer.

Q - We interpret the specs to mean that your mission requires a Radio Room and a Utility Room?

A - We require the trailer to have a radio room and a second room configured as an office space.

Q - Is the exterior entry door into the Utility room?

A - Correct, the exterior door must enter into the office/utility room.

Q - Is there an exterior entry door in the Radio Room?

A - The radio room should not have an exterior door.

Q - Does the Partition wall between rooms requires a door?

A - Yes, the radio room is required to be separated from the office room by a wall with a door to allow for privacy in the radio room.

Q - Do you require the utility room to be at the rear with an additional rear door?

A - The trailer can be configured with the radio room at either end, as long as the trailer's tang and other exterior hardware do not interfere with visibility from the radio room windows.

Q - Would you want full opening barn doors, or a ramp door?

A - The exterior door should be a standard building-style "man door".

Q - Do the windows in the radio room need exterior awnings to cover them when not operational?

A - No. Exterior awnings are not required.

Q - Do the windows need to open?

A - No, the windows do not need to open.

Q - Do you have an extended Height Minimum for the antenna mast?

A - The antenna should extend a minimum of 5 feet above the top of the trailer.

Q - Could you clarify the requirement on the windows for the 180 degree visibility from the radio room, is the requirement for full solid window surface on three sides at one end of trailer or would 3 (large as possible) framed windows, one on each of 3 walls fulfil the requirement?

A - The radio room itself must have windows on 3 sides which allow for 180 degree visibility.

Q - If the 180 degree is framed windows what is the minimum size of each window?

A - There is no minimum window size, preference will be given to trailers with windows that allow for greatest visibility for aviation operations.

Q - What is the required finish of the interior ceiling and walls?

A - There is no requirement for interior finish, preference will be given to surfaces that are durable and easy to clean/maintain.

Q - What is the required finish of the floor?

A - There is no requirement for floor finish, preference will be given to surfaces that are durable and easy to clean/maintain.

Q - Are there requirements for exterior lighting for night operations?

A - Exterior lights are not required to support aviation operations.

Q - Would a trailer in excess of 20' be acceptable? If "yes" what is the maximum length that would work for your application?

A - Yes. The trailer should be between 20' and 28'.

Q - Is there an interior minimum ceiling height requirement?

A - The interior should have a minimum 8 foot ceiling height.

Q - Is the requirement for the generator(s) "portable" or "hard mounted with on-board fuel tank"?

A - Either portable or fixed generators are acceptable.

Q - Is there a requirement for windows in the second room?

A - Yes, the second (non radio room) should have at least one large (minimum 3' x 5', larger preferred) window on one side.

Q - What is the overall height requirement of the mast?

A - The mast should extend at least five (5) feet above the top of the trailer.

Q - What is the operational requirement of the Mast "Manual" or "Pneumatic"?

A - Either is acceptable.

Q - What is the requirement for number of entry doors into trailer?

A - One.